

| | | |
|---|--|----------------------------|
| Requested by: | VIEW SRL Via Monchio, 42/44/46 41042 FIORANO MODENESE (MO) | |
| For the sample: | Ceramic tiles 60 x 60 x 1,0 cm, marked "Serie TIBUR GRIP". | |
| On (date): 24/03/2021 | Date of receipt in laboratory (sample delivered by the client): | 31/03/2021 |
| Sampling details - Where: ----- - Date: ----- - How (methods): ----- | | |
| By whom: CUSTOMER | | |
| Tested in: Sassuolo | Date of starting: 01/04/2021 | Date of ending: 01/04/2021 |

DIN 51130:2004


Determination of the anti – slip properties - Workrooms and fields of activities with raised slip danger, walking method - ramp test

Surface characteristics Smooth Profiled Structured Rough

OPERATIVE CONDITIONS:

Temperature: (23 ± 5) °C
Fixing scheme

walking direction



RESULTS

Average total acceptance angle: 26°
 Movement area (cm³/dm²): Not tested


CLASSIFICATION (DGUV REGEL 108-003)

Group of anti – slip properties: **R11**
 Movement area evaluation group: Not tested

^P Pietro Bruzzi
Technical verification



Prof.ssa Maria Chiara Bignozzi
Director



----- End of report -----

The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. The texts in inverted commas are Customer's declarations and fall under his responsibility. This test report consists of 1 page