

CENTRO DI RICERCA E SPERIMENTAZIONE  
PER L'INDUSTRIA CERAMICA

Requested by:	VIEW SRL Via Monchio, 42/44/46 41042 FIORANO MODENESE (MO)	
For the sample:	Ceramic tiles 60 x 90 x 1,0 cm, marked "SERIE TIBUR".	
On (date): 24/03/2021	Date of receipt in laboratory (sample delivered by the client):	31/03/2021
Sampling details		
- Where:	-----	
- Date:	-----	By whom: CUSTOMER
- How (methods):	-----	
Tested in: Sassuolo	Date of starting: 01/04/2021	Date of ending: 01/04/2021

**DIN 51130:2004**


**Determination of the anti – slip properties - Workrooms and fields of activities with raised slip danger, walking method - ramp test**

Surface characteristics       Smooth       Profiled       Structured       Rough

OPERATIVE CONDITIONS:

Temperature: (23 ± 5) °C  
Fixing scheme

walking direction




RESULTS

Average total acceptance angle: **12°**  
Movement area (cm<sup>3</sup>/dm<sup>2</sup>): Not tested

CLASSIFICATION (DGUV REGEL 108-003)

Group of anti – slip properties: **R10**  
Movement area evaluation group: Not tested

Pietro Bruzzi  
Technical verification



Prof.ssa Maria Chiara Bignozzi  
Director

End of report

The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. The texts in inverted commas are Customer's declarations and fall under his responsibility. This test report consists of 1 page