

<i>Requested by:</i>	VIEW S.r.l. Via Monchio, 42/46 – 41042 FIORANO MODENESE (MO)		
<i>For the sample:</i>	Unglazed ceramic tiles of different sizes marked "Serie DOLOMIA".		
<i>On (date):</i>	15/05/19	<i>Date of receipt in laboratory (sample delivered by the client):</i> 15/05/19	
<i>Test date</i>		<i>From:</i> 17/05/19	<i>To:</i> 17/05/19

DIN 51130 (06/2004) – Determination of the anti – slip properties

Workrooms and fields of activities with raised slip danger, walking method – ramp test

Surface characteristics

- Smooth
- Profiled
- Structured
- Rough

RESULTS

Average total acceptance angle:

13,5°

Movement area (cm³/dm²):


CLASSIFICATION (BGR 181 – 10/2003)

Group of anti – slip properties:

R10

Movement area evaluation group:

Eng. Giordana Carani
Technical approval



Prof. Maria Chiara Bignozzi
Director



The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. This test report consists of 1 pages, this cover included.